Jefferson County Environmental Health
County Sanitarian
901 N 8th St. Fairfield, IA 52556
641-472-2561

Notice of System Reconstruction and Compliance — Time of Transfer

Re: Time of Transfer

Property Address: 1005 Pekin Dr., Packwood, IA 52580

Dear Mr. Sieren: 8/14/2026

This letter is being provided to notify you that the reconstruction of the Ecoflo 600 G system, Serial No. 8AK925, located at the above-referenced property, was completed on August 7, 2026. Chittick Tiling performed the reconstruction using materials and procedures consistent with the manufacturer's requirements and in consultation with the manufacturer of the Ecoflo 600 G system.

The Jefferson County Sanitarian visited the property during the reconstruction phase. Based on the completed work and consultation with the manufacturer, it was determined that the system is now considered to be in compliance with **IAC 567, Chapter 69.1(455B)**.

The property owner may not alter or modify the system without prior notification to, and approval as required by, the Jefferson County Board of Health pursuant to **Jefferson County Ordinance, Chapter 3-10**. Such alterations may include adding, removing, or changing major system components, including tanks or filters, or connecting or reconnecting the system to another drainage structure.

This reconstruction does not eliminate or modify the annual maintenance requirements applicable to the system. The property owner is required by law to maintain a maintenance contract and have the system inspected and maintained annually by a certified maintenance provider. The certified maintenance provider will maintain accurate records and provide them to the Jefferson County Sanitarian and the property owner as required.

Recommended ongoing maintenance includes:

- Annual inspection and maintenance of the system.
- Inspection and cleaning of filters as necessary.
- Inspection of the discharge area and keeping the discharge outlet clear to allow proper discharge.
- Prompt notification to the certified maintenance provider if an alarm condition occurs.

The system is equipped with two high-water alarm indicators: an audible alarm and a red warning light. Either alarm indicates that the water level in the system may be elevated and may signal a malfunction or other conditions requiring attention. If either alarm is activated, the

Jefferson County Environmental Health
County Sanitarian
901 N 8th St. Fairfield, IA 52556
641-472-2561

property owner should promptly contact the certified maintenance provider for inspection and, if necessary, corrective action.

These alarm features provide advance warning of a potentially elevated water level or malfunction within the system and should not be disregarded.

Sincerely,

[Name / Title]